

Our Ref: HL/M120458  
Test Report: MA4317/S section 1

24<sup>th</sup> February 2012

Sirmax SpA.  
Via dell' artigianato 42,  
35013 Cittadella (PD),  
Italy

**WATER REGULATIONS ADVISORY SCHEME (WRAS)**  
**MATERIAL APPROVAL**

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS 6920-1:2000 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

**POLYPROPYLENE**

**5265**

Isoglass H30 FVL (c) NA (beige coloured) & Isoglass H30 FVL (c) BK (black coloured). Injection moulded, glass filled polypropylene material. For use with water up to 85°C.


**APPROVAL NUMBER: 1202507**  
**APPROVAL HOLDER: SIRMAX SPA.**

The Scheme reserves the right to review approval. This approval is valid between February 2012 and February 2017.

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: [www.wras.co.uk/directory](http://www.wras.co.uk/directory)

Yours faithfully



**Jason Furnival**  
**Approvals & Enquiries Manager**  
**Water Regulations Advisory Scheme**